|| Sri Gangamma Krupa ||

ಸಮೃದ್ಧಿ

Kavitha : 99640 02826
Bharath : 98459 88652

Samrudhi Ground Water Consultant

Gangamma Temple Road, Malleshwaram, Bangalore - 560 003.

Date - 16/08/22

REPORT ON GROUND WATER INVESTIGATION

Name : Executive Engineer Project Division

Address : Yelahanka Zone Byrathanayanapura

Location : Bengaluru Topography Black & white

Soil Type : Granite Gneiss Rock Type : Soft rock





RECOMMENDATIONS

Dia of Bore well Bit : 6½" DTH Water Level : 2½ inch

Depth Recommended : 300 to 350 mtr's Yield : 2½ inch

Casing Pipe Required : 35 Mtr's Aquifers : GPH 1500

PVC Other Casing if Required : 30 mtr's Point Location : ☑ ☐ ☐ ☐

Remarks : ———

Rain Water Harvesting Compulsory

Note: The survey was carried out by this divining / Geophysical method of Surveying is with our good Knowledge and experience, However no guarantee of Water will be given

For Samrudhi Ground Water Consultant

Asst. Executive Engineer
Project Division
Yelahanka Zone
...ore - 92

Smt. Kavitha Singh

Scanned by TapScanner